



ST. LOUIS' ORIGINAL
SEARCH ENGINE®

1415 Olive Street
St. Louis, MO 63103
314-241-2288
spl.org

TO: All Proposers
FROM: Rita Kirkland
DATE: August 12, 2021
SUBJECT: Proposal Addendum No. 2
PROPOSAL#: 21-002446
DATE ISSUED: August 2, 2021
THE PROJECT: CHILLER MAINTENANCE – ADMINISTRATIVE OFFICE

INTENT

This addendum is issued to provide a modification/addition to proposal plans and/or specifications.

MODIFICATION / ADDITIONS (Answers to Proposer's Questions)

What are the full model and serial numbers of both chillers?

Model # - YTG3A2C1-CJJ Serial # - GFJM021787
Model# - YKCQCQQ4-CHG Serial # - SBXM-869960

Are both chillers equipped with solid- State starter with drive?

Yes

Is the expectation to perform tube brushing on condenser and evaporator?

Yes

I have read and understand the preceding addendum and said changes are reflected in my proposal. The proposer signed addendum should be included with your response packet.

COMPANY:

PROPOSER'S SIGNATURE:

TITLE:

(Date)

Mission Statement

The St. Louis
Public Library
will provide learning
resources and
information services
that support and
improve individual,
family, and
community life.